

# NEON ENERGY COMPUTER SIMULATION REPORT

## SCOPE OF WORK

ULTRA FIXED WINDOW - NFRC 100/200/500

## REPORT NUMBER

P2835.01-116-45 R1

## TEST DATE

10/26/22

## ISSUE DATE

10/26/22

## REVISION DATE

02/27/23


## PAGES

38

## DOCUMENT CONTROL NUMBER

RT-R-AMER-Test-4044 (04/11/22)

©2017 INTERTEK



## TEST REPORT FOR NEON ENERGY

Report No: P2835.01-116-45 R1

Date: 02/27/23

### REPORT ISSUED TO

#### NEON ENERGY

23 Corporate Plaza

Suite 150

Newport Beach, California 92660

### SECTION 1

#### SUMMARY

#### SERIES/MODEL: Ultra Fixed Window

Architectural Testing, Inc. (an Intertek company) dba Intertek Building & Construction (B&C) was contracted to perform U-Factor, Solar Heat Gain Coefficient, Visible Transmittance and Condensation Resistance simulations in accordance with the National Fenestration Rating Council (NFRC).

This report does not constitute certification of this product nor an opinion or endorsement by this laboratory. Intertek B&C will service this report for the entire test record retention period. The test record retention period ends five years after the test date. Test records, such as detailed drawings, datasheets, representative samples of test specimens, or other pertinent project documentation, will be retained for the entire test record retention period.

FOR INTERTEK B&C:

**COMPLETED BY:** Megan Yingst  
**TITLE:** Simulation Technician  
**SIGNATURE:**  
**DATE:** 02/27/23

**REVIEWED BY:** Eric S. Leitner  
**TITLE:** Manager - Simulations  
and Thermal Testing, SIRC  
**SIGNATURE:**  
**DATE:** 02/27/23

MMY:mmy

---

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample(s) tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

## TEST REPORT FOR NEON ENERGY

Report No: P2835.01-116-45 R1

Date: 02/27/23

### SECTION 2

#### TEST METHODS

The products were evaluated in accordance with the following:

***ANSI/NFRC 100-2020, Procedure for Determining Fenestration Product U-Factors***

***ANSI/NFRC 200-2020, Procedure for Determining Fenestration Product Solar Heat Gain Coefficient and Visible Transmittance at Normal Incidence***

***NFRC 500-2017, Procedure for Determining Fenestration Product Condensation Resistance Values***

*\*Condensation Resistance results obtained from this procedure are for controlled laboratory conditions and do not include the effects of air movement through the specimen, solar radiation, and the thermal bridging that may occur due to the specific design and construction of the fenestration system opening.*

Ratings values included in this report are for submittals to an NFRC-licensed IA and are not meant to be used directly for labeling purposes. Only those values identified on a valid Certificate of Authorization (CA) by an NFRC accredited Inspection Agency (IA) are to be used for labeling purposes. The ratings values were rounded in accordance with NFRC 601, NFRC Unit and Measurement Policy.

Intertek B&C is an NFRC accredited simulation laboratory and all simulations were conducted in full compliance with NFRC approved procedures and specifications. The values included in this report are not considered in compliance with ANSI/NFRC 100, ANSI/NFRC 200, and/or NFRC 500 unless the associated validation test requirements have been satisfied, as applicable.

**TEST REPORT FOR NEON ENERGY**

Report No: P2835.01-116-45 R1

Date: 02/27/23

**SECTION 3**

**TEST PROCEDURE**

The total product, including specific frame, spacer, and glass details, was modeled using NFRC approved software.

<b>FRAME AND EDGE MODELING</b>	THERM 7.4.4
<b>CENTER-OF-GLASS MODELING</b>	WINDOW 7.4.14
<b>TOTAL PRODUCT CALCULATIONS</b>	WINDOW 7.4.14
<b>SPECTRAL DATA LIBRARY</b>	IGDB 90.0

**Modeling Assumptions / Technical Interpretations**

Any modeling assumptions and technical interpretations required to model this product are listed below.

- 1) To prevent air infiltration, tape was applied to all interior sash crack locations.
- 2) TVO-921, TVO-922 and TVO-927 frame options were grouped per ANSI/NFRC 100-2020, Section 4.2.1.H.ii. TVO-927 is the group leader.
- 3) The anodized and painted aluminum finishes were grouped per ANSI/NFRC 100-2020, Section 4.2.1.L. The painted finish is the group leader.

**SECTION 4**

**SIMULATION SPECIMEN DESCRIPTION**

<b>SERIES/MODEL</b>	Ultra Fixed Window
<b>PRODUCT TYPE</b>	Fixed (Picture Window)
<b>FRAME MATERIAL</b>	AT - Aluminum w/ Thermal Breaks - All Members
<b>SASH MATERIAL</b>	NA - Not Applicable
<b>STANDARD SIZE</b>	1200mm x 1500mm

## TEST REPORT FOR NEON ENERGY

Report No: P2835.01-116-45 R1

Date: 02/27/23

### SECTION 4 (Continued)

#### SIMULATION SPECIMEN DESCRIPTION

SPACER OPTIONS			
TYPE	PRIMARY SEAL	SECONDARY SEAL	CODE
Aluminum Spacer	Butyl Rubber	Butyl Rubber	A1-D
Thermix TX.N Plus Spacer	Butyl Rubber	Silicone	TS-D

GRID OPTIONS		
GRID SIZE	GRID TYPE	GRID PATTERN
None	-	-

REINFORCEMENT OPTIONS	
LOCATION	MATERIAL
None	-

GAS FILLING TECHNIQUE	
FILL TYPE	METHOD
90% Argon	Two-probe with concentration sensor

EDGE-OF-GLASS CONSTRUCTION	
INTERIOR CONDITION	EPDM gasket between glass and glazing bead
EXTERIOR CONDITION	EPDM gasket between glass and aluminum frame

WEATHERSTRIPPING		
TYPE	QUANTITY	LOCATION
None	-	-

FRAME/SASH MATERIALS FINISH	
INTERIOR	Aluminum - Painted or Anodized
EXTERIOR	Aluminum - Painted or Anodized

VALIDATION MATRIX*	
PRODUCT LINE	REPORT NUMBER
None	-

\*These products are part of a validation matrix. Only one is required for validation testing.

**TEST REPORT FOR NEON ENERGY**

Report No: P2835.01-116-45 R1

Date: 02/27/23

**SECTION 5**

**SPECIALTY PRODUCTS TABLE**

The specialty products method allows the manufacturer to determine the overall product SHGC and VT for any glazing option. The center of glass SHGC and/or VT must be determined using WINDOW 7.4.14. The method calculates overall product SHGC and VT indexed on center of glass properties. All values used in the calculations are truncated to six decimal place precision.

	No Dividers	Dividers < 1	Dividers > 1
<b>SHGC0</b>	0.002873	0.005769	0.008505
<b>SHGC1</b>	0.845549	0.760536	0.680203
<b>VT0</b>	0.000000	0.000000	0.000000
<b>VT1</b>	0.842675	0.754767	0.671698

$$SHGC = SHGC0 + SHGCc (SHGC1 - SHGC0)$$

$$VT = VT0 + VTc (VT1 - VT0)$$

## TEST REPORT FOR NEON ENERGY

Report No: P2835.01-116-45 R1

Date: 02/27/23

### SECTION 6

### SIMULATION RESULTS

TOTAL PRODUCT CALCULATIONS (Ultra Fixed Window)												
Option Number	Pane Thickness 1 (in)	Gap Width 1 (in)	Pane Thickness 2 (in)	Gap Width 2 (in)	Pane Thickness 3 (in)	Gap Width 3 (in)	Pane Thickness 4 (in)	Gap Fill	Low-e (Surface #)	Tint	Spacer	Grid Type
	U-Factor (Btu/Hr-Ft2-F)			Solar Heat Gain Coefficient (SHGC) Grids (None / <1 / >=1)				Visible Transmittance (VT) Grids (None / <1 / >=1)		Condensation Resistance (CR)		
1	SNX50/ARG90/CLR (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.027(#2)	CL	A1-D	N
	U-Factor 0.32			SHGC(N) 0.19				VT(N) 0.42		CR 48		
2	SNX60/ARG90/CLR (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.026(#2)	CL	A1-D	N
	U-Factor 0.32			SHGC(N) 0.23				VT(N) 0.50		CR 48		
3	SN4023/ARG90/CLR (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.026(#2)	CL	A1-D	N
	U-Factor 0.32			SHGC(N) 0.19				VT(N) 0.34		CR 48		
4	SN7037/ARG90/CLR (6MM/6MM) - 28MM IG											
	0.230	0.630	0.230					ARG90	0.022(#2)	CL	A1-D	N
	U-Factor 0.32			SHGC(N) 0.29				VT(N) 0.59		CR 48		
5	SN7037/ARG90/CLR (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.022(#2)	CL	A1-D	N
	U-Factor 0.32			SHGC(N) 0.29				VT(N) 0.59		CR 48		
6	SNX50/ARG90/CG-Dry (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.027(#2) / 0.200(#4)	CL	TS-D	N
	U-Factor 0.27			SHGC(N) 0.18				VT(N) 0.40		CR 51		
7	SNX50/ARG90/CG-Premium2T (6MM/6MM) - 28MM IG											
	0.230	0.630	0.230					ARG90	0.027(#2) / 0.041(#3)	CL	TS-D	N
	U-Factor 0.30			SHGC(N) 0.19				VT(N) 0.41		CR 54		
8	SNX60/ARG90/CG-Dry (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.026(#2) / 0.200(#4)	CL	TS-D	N
	U-Factor 0.27			SHGC(N) 0.22				VT(N) 0.49		CR 51		
9	SNX60/ARG90/CG-Premium2T (6MM/6MM) - 28MM IG											
	0.230	0.630	0.230					ARG90	0.026(#2) / 0.041(#3)	CL	TS-D	N
	U-Factor 0.30			SHGC(N) 0.23				VT(N) 0.49		CR 54		
10	SN4023/ARG90/CG-Dry (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.026(#2) / 0.200(#4)	CL	TS-D	N
	U-Factor 0.27			SHGC(N) 0.18				VT(N) 0.33		CR 51		

## TEST REPORT FOR NEON ENERGY

Report No: P2835.01-116-45 R1

Date: 02/27/23

### SECTION 6 (Continued)

### SIMULATION RESULTS

TOTAL PRODUCT CALCULATIONS (Ultra Fixed Window)												
Option Number	Pane Thickness 1 (in)	Gap Width 1 (in)	Pane Thickness 2 (in)	Gap Width 2 (in)	Pane Thickness 3 (in)	Gap Width 3 (in)	Pane Thickness 4 (in)	Gap Fill	Low-e (Surface #)	Tint	Spacer	Grid Type
	U-Factor (Btu/Hr-Ft2-F)			Solar Heat Gain Coefficient (SHGC) Grids (None / <1 / >=1)				Visible Transmittance (VT) Grids (None / <1 / >=1)		Condensation Resistance (CR)		
11	SN4023/ARG90/CG-Premium2T (6MM/6MM) - 28MM IG											
	0.230	0.630	0.230					ARG90	0.026(#2) / 0.041(#3)	CL	TS-D	N
	U-Factor 0.30			SHGC(N) 0.19				VT(N) 0.33		CR 54		
12	SN51/ARG90/CG-Dry (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.026(#2) / 0.200(#4)	CL	TS-D	N
	U-Factor 0.27			SHGC(N) 0.21				VT(N) 0.41		CR 51		
13	SN51/ARG90/CG-Premium2T (6MM/6MM) - 28MM IG											
	0.230	0.630	0.230					ARG90	0.026(#2) / 0.041(#3)	CL	TS-D	N
	U-Factor 0.30			SHGC(N) 0.22				VT(N) 0.42		CR 54		
14	SN7037/ARG90/CG-Dry (6MM/6MM) - 28MM IG											
	0.230	0.630	0.230					ARG90	0.022(#2) / 0.200(#4)	CL	TS-D	N
	U-Factor 0.26			SHGC(N) 0.28				VT(N) 0.57		CR 52		
15	SN7037/ARG90/CG-Premium2T (6MM/6MM) - 28MM IG											
	0.230	0.630	0.230					ARG90	0.022(#2) / 0.041(#3)	CL	TS-D	N
	U-Factor 0.30			SHGC(N) 0.29				VT(N) 0.58		CR 54		
16	SN7037/ARG90/CG-Dry (6MM/5MM) - 27MM IG											
	0.230	0.630	0.191					ARG90	0.022(#2) / 0.200(#4)	CL	TS-D	N
	U-Factor 0.26			SHGC(N) 0.28				VT(N) 0.57		CR 52		
17	SN7037/ARG90/CG-Premium2T (6MM/4MM) - 26MM IG											
	0.230	0.630	0.151					ARG90	0.022(#2) / 0.041(#3)	CL	TS-D	N
	U-Factor 0.30			SHGC(N) 0.29				VT(N) 0.58		CR 54		
18	SN7037/ARG90/CLR/ARG90/CGPremium2T (6MM/5MM/6MM) - 39MM IG											
	0.230	0.394	0.191	0.472	0.230			ARG90	0.022(#2) / 0.041(#5)	CL	TS-D	N
	U-Factor 0.20			SHGC(N) 0.27				VT(N) 0.53		CR 53		
19	SNX60/ARG90/CLR/ARG90/CGPremium2T (6MM/5MM/6MM) - 39MM IG											
	0.230	0.394	0.191	0.472	0.230			ARG90	0.026(#2) / 0.041(#5)	CL	TS-D	N
	U-Factor 0.20			SHGC(N) 0.21				VT(N) 0.45		CR 53		
20	SNX60/ARG90/CLR/ARG90/CGPremium2T (6MM/4MM/4MM) - 36MM IG											
	0.230	0.394	0.151	0.472	0.151			ARG90	0.026(#2) / 0.041(#5)	CL	TS-D	N
	U-Factor 0.20			SHGC(N) 0.21				VT(N) 0.45		CR 53		



## TEST REPORT FOR NEON ENERGY

Report No: P2835.01-116-45 R1

Date: 02/27/23

### SECTION 6 (Continued)

### SIMULATION RESULTS

TOTAL PRODUCT CALCULATIONS (Ultra Fixed Window)																	
Option Number	Pane Thickness 1 (in)	Gap Width 1 (in)	Pane Thickness 2 (in)	Gap Width 2 (in)	Pane Thickness 3 (in)	Gap Width 3 (in)	Pane Thickness 4 (in)	Gap Fill	Low-e (Surface #)	Tint	Spacer	Grid Type					
	U-Factor (Btu/Hr-Ft <sup>2</sup> -F)		Solar Heat Gain Coefficient (SHGC) Grids (None / <1 / >=1)				Visible Transmittance (VT) Grids (None / <1 / >=1)		Condensation Resistance (CR)								
21	SN7037/ARG90/CLR-LAMI (6MM/5MM 0,38PVB 5MM) - 32MM IG																
	0.230	0.630	0.379					ARG90	0.022(#2)	CL	TS-D	N					
	U-Factor		0.31		SHGC(N)			0.29		VT(N)		0.57		CR		52	



Total Quality. Assured.

130 Derry Court  
York, Pennsylvania 17406

Telephone: 717-764-7700  
Facsimile: 717-764-4129  
[www.intertek.com/building](http://www.intertek.com/building)

**TEST REPORT FOR NEON ENERGY**

Report No: P2835.01-116-45 R1


Date: 02/27/23

**SECTION 7**

**DRAWINGS / BILL OF MATERIALS**

The drawings which follow have been reviewed by Intertek B&C and are representative of the simulation results reported herein. Any deviations are documented herein or on the drawings.


# Fixed



# Section A-A, B-B

## Frame TVO-921


 intertek	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B

## Frame TVO-921


	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B


## Frame TVO-921

 intertek	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>




# Section A-A, B-B

## Frame TVO-921

	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>

EXTERIOR


INTERIOR



# Section A-A, B-B

## Frame TVO-921

	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>






# Section A-A, B-B Frame TVO-921


# Specimen


 intertek	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B

## Frame TVO-922


 intertek	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B


## Frame TVO-922


	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B

## Frame TVO-922


	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B

## Frame TVO-922


	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B

## Frame TVO-922

 intertek	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B


## Frame TVO-922



Report #: P2835-116-45


Date: 10/26/2022


Verified by: *Megan M. Young*



# Section A-A, B-B

## Frame TVO-927


	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>





# Section A-A, B-B Frame TVO-927


	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B

## Frame TVO-927

 intertek	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B


## Frame TVO-927



Report #: P2835-116-45

Date: 10/26/2022


Verified by: *Megan M. Young*



# Section A-A, B-B

## Frame TVO-927


 intertek	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>



# Section A-A, B-B

## Frame TVO-927

	Report #: P2835-116-45
	Date: 10/26/2022
	Verified by: <i>Megan M. Young</i>





Total Quality. Assured.

130 Derry Court  
York, Pennsylvania 17406

Telephone: 717-764-7700  
Facsimile: 717-764-4129  
www.intertek.com/building

**TEST REPORT FOR NEON ENERGY**

Report No: P2835.01-116-45 R1

Date: 02/27/23

**SECTION 8**

**REVISION LOG**

<b>REVISION #</b>	<b>DATE</b>	<b>PAGES</b>	<b>REVISION</b>
.01R0	10/26/22	All	Original report issued to Neon Energy
.01R1	02/27/23	All	Fixed glass emissivity on some models and updated results (Options #1 &6)